



**IEH ANALYTICAL LABORATORIES**  
**LABORATORY & CONSULTING SERVICES**  
3927 AURORA AVENUE NORTH, SEATTLE, WA 98103  
PHONE: (206) 632-2715 FAX: (206) 632-2417

<b>CASE FILE NUMBER:</b>	<b>SAN007-97</b>	<b>PAGE 1</b>
<b>REPORT DATE:</b>	<b>06/30/17</b>	
<b>DATE SAMPLED:</b>	<b>06/12/17</b>	<b>DATE RECEIVED: 06/13/17</b>
<b>FINAL REPORT, LABORATORY ANALYSIS OF SELECTED PARAMETERS ON WATER</b>		
<b>SAMPLES FROM IEH SANIPURE / SOUTH HACKENSACK BOARD OF EDUCATION</b>		

**CASE NARRATIVE**

Two water samples were received by the laboratory in good condition and analyzed according to the chain of custody. No difficulties were encountered in the preparation or analysis of these samples. Sample data follows while QA/QC data is contained on the subsequent pages.

**SAMPLE DATA**

SAMPLE DESCRIPTION	SAMPLE ID	LEAD (ug/L)
RM104 7:55AM	ISP-061217-009	19.8
RM104 8:05AM	ISP-061217-010	1.7



**IEH ANALYTICAL LABORATORIES**  
**LABORATORY & CONSULTING SERVICES**  
 3927 AURORA AVENUE NORTH, SEATTLE, WA 98103  
 PHONE: (206) 632-2715 FAX: (206) 632-2417

<b>CASE FILE NUMBER:</b>	<b>SAN007-97</b>	<b>PAGE 2</b>
<b>REPORT DATE:</b>	<b>06/30/17</b>	
<b>DATE SAMPLED:</b>	<b>06/12/17</b>	<b>DATE RECEIVED: 06/13/17</b>
<b>FINAL REPORT, LABORATORY ANALYSIS OF SELECTED PARAMETERS ON WATER</b>		
<b>SAMPLES FROM IEH SANIPURE / SOUTH HACKENSACK BOARD OF EDUCATION</b>		

**QA/QC DATA**

QC PARAMETER	LEAD (ug/L)
METHOD	EPA 200.8
DATE ANALYZED	06/14/17
REPORTING LIMIT	2.0
DUPLICATE	
SAMPLE ID	BATCH
ORIGINAL	<2.0
DUPLICATE	<2.0
RPD	NC
SPIKE SAMPLE	
SAMPLE ID	BATCH
ORIGINAL	<2.0
SPIKED SAMPLE	48.5
SPIKE ADDED	50.0
% RECOVERY	96.93%
QC CHECK	
FOUND	49.4
TRUE	50.0
% RECOVERY	98.76%
BLANK	<2.0

RPD = RELATIVE PERCENT DIFFERENCE.  
 NA = NOT APPLICABLE OR NOT AVAILABLE.  
 NC = NOT CALCULABLE DUE TO ONE OR MORE VALUES BEING BELOW THE DETECTION LIMIT.  
 OR = RECOVERY NOT CALCULABLE DUE TO SPIKE SAMPLE OUT OF RANGE OR SPIKE TOO LOW RELATIVE TO SAMPLE CONCENTRATION.

SUBMITTED BY:

*Mitchell W. Kiriluk*

Mitchell W. Kiriluk  
 Project Manager