

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM's April 28, 2025 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

Memorial School

Lead in drinking water measurements were collected in seven (7) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
25-0428-01	2 nd Floor Hall (Water Fountain Left)	None Detected
25-0428-02	2 nd Floor Hall (Water Fountain Right)	None Detected
25-0428-03	Adjacent Gym (Water Fountain Left)	None Detected
25-0428-04	Adjacent Gym (Water Fountain Right)	None Detected
25-0428-05	Hallway by Room 106 (Water Fountain)	None Detected
25-0428-06	Cafeteria (Water Fountain Left)	None Detected
25-0428-07	Cafeteria (Water Fountain Right)	None Detected

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : RAMM Environmental Services, INC
77 Nottingham Road
Fair Lawn, NJ 07410

Project ID : Memorial School, 1 Dyer Ave, S. Hackensack, NJ
PAS Project ID : P25-03386

Matrix : Drinking Water
Report Date : 5/9/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03386-01	Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:30	5/2/25 19:17
P25-03386-02	2nd Floor Hall Water Fountain Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:33	5/2/25 19:22
P25-03386-03	2nd Floor Hall Water Fountain Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:35	5/2/25 19:26
P25-03386-04	By the Gym Water Fountain Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:37	5/2/25 19:30
P25-03386-05	By the Gym Water Fountain Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:40	5/2/25 19:34
P25-03386-06	Hallway by Room #106 Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:42	5/2/25 19:46
P25-03386-07	Cafeteria Water Fountain Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:45	5/2/25 20:02
P25-03386-08	Cafeteria Water Fountain Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/28/25 08:47	5/2/25 20:06

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

CHAIN OF CUSTODY

##

#VALUE!

Customer: RAMM Environmental Services
Address: 77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Phone: 201-475-9880

School Name: Remond School, South Hackensack
School Address: 1 DYER AVE, SOUTH HACKENSACK, NJ
Sampled By: [Signature]
Print Name: VLADO VIKOZOSKI
RESULTS TO: rammenvironmental@gmail.com

Sample ID	Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Fiber Present	# Containers	Glass or Plastic	Analysis	LAB ID
B.	Blank	2/18/25 8:30	DW	Grab	NO	-	1	250 ml Plastic	Lead	P25-03386-01
1	1st Floor Hallway	8:33	DW	Grab	NO	-	1	250 ml Plastic	Lead	-02
2	2nd Floor Hallway - on the left	8:35	DW	Grab	NO	-	1	250 ml Plastic	Lead	-03
3	By the Gym - under bench	8:37	DW	Grab	NO	-	1	250 ml Plastic	Lead	-04
4	By the Gym - under bench	8:40	DW	Grab	NO	-	1	250 ml Plastic	Lead	-05
5	Hallway by room 106	8:42	DW	Grab	NO	-	1	250 ml Plastic	Lead	-06
6	Cafeteria - under bench	8:45	DW	Grab	NO	-	1	250 ml Plastic	Lead	-07
7	Cafeteria - under bench - right	8:47	DW	Grab	NO	-	1	250 ml Plastic	Lead	P25-03386-08
8		8:51	DW	Grab	NO	-	1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page of Deliverables: PDF Std. ☒ X PDF Reduce PDF Full EDD ☒ Date/Time Preserved with HNO3: Trace TAT

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify): Norex All samples preserved with HNO3

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	VLADO VIKOZOSKI	[Signature]	RAMM	02/18/25
Received:	Perry Helgas	[Signature]	RAMM	10:30
Relinquished:	Perry Helgas	[Signature]	RAMM	2/18/25
Received:				4/28/25
Relinquished:				
Received:				

Total OF 07 samples plus 1 blank.